



No. F.6/DFS/MS/School/2025/SZ/ 974

Dated: 11/08/2025

**FIRE SAFETY CERTIFICATE**

Certified that the building of **Delhi International School Edge** located at Sector-18, Dwarka Phase-II, New Delhi-110075, comprised of **Ground plus three upper floors**, owned/occupied by Great Harsh Educational Welfare & Charitable Society, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/SZ/2021/639 dated 24/08/2021. The premise was re-inspected by the officer concerned of this department on dated 17/07/2025 in the presence of Sh. Naresh Kumar (Transport In-charge) and found that said **premises/building is fit for occupancy class "Educational Group B"** (School) with effect from 11/08/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 11/08/2025 at New Delhi by

  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
2. ~~Authorized Signatory, Delhi International School located at Sector-18, Dwarka Phase-II, New Delhi-110075~~
3. The Chairman, DDA, Vikas Sadan, INA, New Delhi.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The building sanctioning authority may verify the authorization of covered courtyard, however, the same has been protected with smoke venting arrangements.