




MUNICIPAL CORPORATION OF DELHI  
OFFICE OF DEPUTY HEALTH OFFICER  
NAJAFGARH ZONE



No: DHO/NGZ/MCD/2026/D-135

Dated 28/04/2026

SCHOOL HEALTH CERTIFICATE

1. Name of the School: - DELHI INTERNATIONAL SCHOOL EDGE
2. SCHOOL ADDRESS:- SEC-18, DWARKA NEW DELHI-110075.
3. NO. OF SHIFT ONE TIMING Morning. 08:00 AM TO 02:00 PM
4. NO. OF STUDENTS: BOYS- 893 GIRLS - 643 TOTAL = 1536
5. NO. OF STAFFS: MALE - 07 FEMALE - 86 TOTAL = 93

Details of Accommodations present in School

1. Floor Space in the Classroom Sufficient/insufficient **SUFFICIENT**
2. The Classrooms are Well Lighted/ill lighted **WELL LIGHTED**
3. The Classrooms are Well Ventilated/ill ventilated **WELL VENTILATED**
4. The Classrooms are kept / Not kept Neat & Clean: **NEAT AND CLEAN**
5. The Building requires/does not required Whitewash etc. **NOT REQUIRED**
6. The Drinking Water is Wholesome/Not wholesome **WHOLESOME**
7. The Latrine arrangement is Sanitary/Insanitary **SANITARY FROM HEALTH POINT OF VIEW.**

No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is **SUFFICIENT**
2. One latrine for 40 male student is required so total is **SUFFICIENT**
3. Separate Toilet arrangement for staff present: Yes/No **YES SEPARATE EXISTS FOR STAFF.**
4. The Overall facilities: Good/ Adequate/Inadequate **GOOD FROM HEALTH POINT OF VIEW.**

*If building Department or any other govt. agency takes actions against u/a construction or any dispute, then the Health Certificate will be stand cancelled /revoked without any further intimation in this regard*

Deputy Health Officer  
Najafgarh Zone  
Municipal Corporation Of Delhi  
Health Deptt., Najafgarh Zone

*(Remarks: This Certificate is valid for one year from the date of issue and this has no bearing on any unauthorized construction)*

Note: - (This certificate Valid for School run in upper Ground + 3 upper floors only as per Fire NOC)



**DELHI JAL BOARD**  
( GOVT. OF N.C.T. DELHI )  
**QUALITY CONTROL LABORATORY,**  
**WATER TREATMENT PLANT NANGLOI , DELHI-110041**



International Year  
of Cooperatives  
Cooperatives Build a Better World

Water Sample analysis report of samples collected from "Delhi International School Edge" Sector-18, Dwarka, New Delhi - 110075 Vide challan no: - 108 dated: - 21.07.2025.

S1: DJB Stored water at above site.

S2: Drinking Point (R.O.) at above site.

S. No.	Particulars <b>THE TEST REPORT IS FOR THIS PARTICULAR WATER SAMPLE ONLY.</b>	Units	Limit		S1	S2
			Acceptable	Permissible		
<b>PHYSICAL EXAMINATION</b>						
1.	Date of collection	-----	--	--	31.07.25	31.07.25
2.	Date of Analysis	-----	--	--	02.08.25	02.08.25
3.	Colour	CU	5.0	15	Clear	Clear
4.	Odour	-----	No. Objectionable		No Obj.	No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	3.0	1.0
6.	PH value	-----	6.5	8.5	7.58	7.48
7.	Electrical Conductivity	µmho/cm	--	--	279.5	196.5
8.	Total dissolved solids	mg/l	500	2000	181.7	127.7
<b>CHEMICAL EXAMINATION</b>						
9.	Phenolphthalein Alkalinity	mg/l	--	--	NIL	NIL
10.	Total Alkalinity	mg/l	200	600	67	46
11.	Total Hardness	mg/l	200	600	108	66
12.	Calcium Hardness	mg/l	--	--	76	32
13.	Magnesium Hardness	mg/l	--	--	32	34
14.	Calcium as Ca	mg/l	75	200	30.4	12.8
15.	Magnesium as Mg	mg/l	30	100	7.68	8.16
16.	Ammonia as N	mg/l	0.5	N.R.	NIL	NIL
17.	Nitrite as N	mg/l	---	--	NIL	NIL
18.	Nitrate as No <sub>3</sub>	mg/l	45	N.R.	2.8	1.8
19.	Sulphate	mg/l	200	400	30	10
20.	Chloride	mg/l	250	1000	28	26
21.	Fluoride	mg/l	1	1.50	0.28	0.10
22.	Dissolve Iron	mg/l	1	N.R.	0.14	0.02
23.	Cyanide	mg/l	0.05	N.R.	ND	ND
24.	Residual Chlorine	mg/l	0.20(min)	1.0	0.30	NIL
<b>BACTERIOLOGICAL EXAMINATION</b>						
25.	Coli-form per 100 ml at 37°C	MPN	0		0	0

REMARKS: As per tested parameters Sample S-1 & S-2 can be used for drinking purpose.

*S. Pandey*  
**ACWA**  
Asstt. Chief Water Analyst  
**DELHI JAL BOARD**  
Govt. of N.C.T. Delhi  
Quality Control Laboratory  
Wari, Nangi  
110041

*[Signature]*  
**BACT.**

*[Signature]*  
**A/CHEMIST**